





NOTES: UNLESS OTHERWISE SPECIFIED.

- 1. PRECAST MATERIALS AND MANUFACTURING METHODS SHALL CONFORM TO ASTM C-478.
- 2. CONCRETE SHALL HAVE A MINIMUM COMPRESSIVE STRENGTH F C= 4000 PSI AT 28 DAYS. MIX DESIGN # 1419017, MIX DESCRIPTION 660-CW-4000P PRE-CON MIX.
- 3. THE PORTLAND CEMENT USED IN THE PRECAST SECTIONS SHALL MEET THE REQUIREMENTS OF TYPE II/V HIGH SULFATE RESISTANT CEMENT IN ACCORDANCE WITH ASTM C-150.
- 4. LANE EZ LIFT PINS, A-ANCHOR AND CONAC A-ANCHORS ARE USED FOR LIFTING. GROUT OVER HOLES AFTER INSTALLATION OF MAINTENANCE HOLES.
- 5. REINFORCEMENT STEEL AREA 0.12 SQ./FT FOR STANDARD SHAFTING AND AREA 0.18 SQ./FT FOR DRAIN MODULES AND BASE. SEE DETAIL ON SHEETS 1 AND 2.
- 6. MAXIMUM HEIGHT 50 FEET, SEE PROJECT PLANS IF THE HEIGHT EXCEEDS 50 FEET.
- 7. ALL JOINTS TO BE SEALED USING APPROVED PREFORMED FLEXIBLE JOINT SEALANT. SEALANT SHALL MEET OR EXCEED ASTM C 990.
- 8. DRYWELL SHALL BE PROVIDED WITH MINIMUM 30-INCH FRAME AND COVER IN ACCORDANCE WITH STANDARD PLAN S-283-0.
- 9. MANHOLE COMPLIES WITH HS20 TRAFFIC LOADING.
- 10. THE STRUCTURE WAS NOT DESIGNED TO RECEIVE SURCHARGE LOADS FROM ADJACENT STRUCTURES OR RAILROAD LOADS.
- 11. CONTACT BUREAU OF CONTRACT ADMINISTRATION MATERIAL CONTROL SECTION AT (213) 485-5080 FOR FABRICATION INSPECTION.
- 12. A COPY OF PRODUCTION APPROVAL TO BE AVAILABLE AT PRECON
- PRODUCTS MANUFACTURING PLANT AND JOB SITE AT ALL TIMES.
- 13. SEE PROJECT PLANS FOR CONNECTOR PIPE SIZE, TYPE AND INVERT ELEVATIONS.
- 14. SEE PROJECT PLANS FOR CHAMBER ELEVEATIONS.
- 15. DRAIN HOLES AS REQUIRED BY PLANS.



WWW.PRE-CONPRODUCTS.COM

THE CONTENTS OF THESE DRAWINGS
ARE THE PROPERTY OF PRECON PRODUCTS
AND ARE PROFICTARY AND CONFIDENTIAL.
THESE DOCUMENTS SHALL NOT BE
DISSMINATED FOR ANY OTHER USE,
WITHOUT THE WRITTEN CONSENT OF
PRECON PRODUCYS. IF YOU RECEIVE
THESE DRAWINGS IN ERROR, RETURN
TO SENDER WITHOUT READING, COPYING
OR DISCLOSING THE CONTENTS.

DATE:

1/2/2019

48" INFILTRATION DRYWELL, 5" WALL LA CITY DRAINAGE SYSTEM SHEETS:

3 OF 3

DO NOT SCALE